



YS

NOTES:

1. TYPICAL PIPING LAYOUT WHEN LINE REGULATOR IS MOUNTED NOT MORE THAN TEN FEET FROM CARBURATOR.
2. FOR LP VAPOR, USE THE SAME REGULATOR, BUT REMOVE THE REGULATOR SPRING AND MOUNT UPSIDE DOWN.

KATOLIGHT
 MINNAPOTA, MINNESOTA

NG OR LP VAPOR FUEL SYSTEM

SIZE	DATE	DWG NO	204-206-11-1
B	6-29-95		
DESCRIPTION			IMP/CO SHEET 1 OF 1