

THIS DRAWING AND THE DATA DISCLOSED HEREIN OR HEREWITH IS CONFIDENTIAL AND PROPRIETARY AND IS NOT TO BE REPRODUCED, USED, OR DISCLOSED IN WHOLE OR IN PART TO ANYONE WITHOUT THE EXPRESSED WRITTEN PERMISSION OF MULTIQUIP COMPANY.


DWG. NO. 200163 | REVISION D

REVISIONS				
ZONE	LTR	DESCRIPTION	DATE	APPROVED
	D	CHANGED THE SCALE ON VIEW "A" & PANEL	12-6-01	JT







VIEW "A"
(SCALE: 3=1)



PANEL
(SCALE: 3=1)



FRONT VIEW



LEFTSIDE VIEW

MATERIAL LIST				
ITEM	PART NUMBER	QTY	DESCRIPTION	MANUFACTURER
1	E1016-1730	3	FEMALE DOUBLE SET-SCREW (WHITE)	CAM-LOK
2	E1016-1729	3	FEMALE DOUBLE SET-SCREW (GREEN)	CAM-LOK
3	E1016-1727	3	FEMALE DOUBLE SET-SCREW (RED)	CAM-LOK
4	E1016-1725	3	FEMALE DOUBLE SET-SCREW (BLACK)	CAM-LOK
5	E1016-1731	3	FEMALE DOUBLE SET-SCREW (BLUE)	CAM-LOK
6	200178	1	THREE CONDUCTORS CAMLOKS PANEL	MQP
7	A100895-1	15	SNAP BACK COVER	CAM-LOK
8	100444	30	SPACERS	CAM-LOK

NOTES:

1. CAMLOK CONNECTORS RATED UP TO 400 AMPERES.
2. ACCEPTS CABLE SIZE FROM #2 – 4/0.
3. OPTIONAL SNAP BACK COVER – INCLUDED.
4. FACTORY LUG CONNECTIONS REMOVED.
5. ADD THREE CONDUCTOR CAMLOKS PER PHASE.

UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES TOLERANCES ARE : FRACTIONS ± DECIMALS .XX ± .XXX ± ANGLES ±	CUSTOMER	MQ POWER			
	JOB NO.	TEL: (310) 537-3700/FAX: (310) 632-2656 18910 WILMINGTON AVENUE CARSON, CA 90746			
	APPROVALS	DATE			
DERIVED FROM	MATERIAL	DRAWN J. TRAN	4-23-01	OUTLINE-DCA 300SSK CAMLOK OUTPUT	
REV D / DATE 12-6-01	FINISH	CHECKED J. ROSE	4-23-01	SIZE D / FSCM NO. / DWG. NO. 200163	
CAD CODE 200163	DO NOT SCALE DRAWING	SALESMAN		SCALE 1 = 14	SHEET 1 / 1

200163 D