








CONTROL PANEL	
NO.	NAME
1	FREQUENCY METER
2	AC AMMETER
3	AC VOLTMETER
4	ALARM LAMP (OIL PRESS., WATER TEMP., CHARGING, PRE-HEAT)
5	MANUAL SPEED CONTROL
6	VOLTAGE REGULATOR
7	HOOR METER
8	AC CIRCUIT BREAKER
9	STARTER SWITCH
10	GROUNDING TERMINAL (FOR G.F.C.I.)
11	OUTPUT RECEPTACLE DUPLEX, (NEMA 5-20R G.F.C.I.)
12	OUTPUT RECEPTACLE (NEMA L530R)
13	OUTPUT RECEPTACLE (NEMA L630R)
14	OUTPUT RECEPTACLE (NEMA CS6389)



- NOTES:
1. C.G. CENTER OF GAVITY
 2. * AREA FOR AIR DISCHARGE: APPROX. 0.7 sq ft

ENGINE	: ISUZU 3LB1
GENERATOR	:
BATTERY	: 12V-70Ah
FUEL TANK	: 13.5
NET WEIGHT	: Approx. 948lbs

UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES TOLERANCES ARE :		CUSTOMER		MQ POWER TEL: (310) 537-3700/FAX: (310) 632-2656 18910 WILMINGTON AVENUE CARSON, CA 90746
FRACTIONS ±	DECIMALS .XX ± .XXX ±	ANGLES ±		
DERIVED FROM DENYO CO.		MATERIAL		JOB NO.
REV 4	DATE 10-12-00	FINISH		APPROVALS DRAWN J. TRAN
CAD CODE 200047		DO NOT SCALE DRAWING		CHECKED J. ROSE
				SALESMAN
				DATE
				OUTLINE DRAWING TLG 12SPX3
				SIZE D
				FSCM NO. 23980
				DWG. NO. 200047
				SCALE 1" = 10"
				SHEET 1 / 1