

JOB #	TANK CAPACITY	GENSET MODEL	GENSET FOOTPRINT	TANK WEIGHT
10406	15 GAL	DCA10SPX3	X	350 LBS


APPROVED BY: _____ DATE: _____





BILL OF MATERIAL

LETTER	PART #	DESCRIPTION	QTY
S	3162	FLANGE, 2", EMERGENCY VENT	2
T	3650	FLANGE, 2", RETURN, W/ 1/2" DIPTUBE	1
U	3650	FLANGE, 2", SUPPLY, W/ 1/2" DIPTUBE	1
V	1000	FLANGE, 2", LOW LEVEL	1
X	1003	FLANGE, 2", FUEL LEVEL GAUGE	1
Y	3152	FLANGE, 2", STANDARD VENT	2
Z	3005	FLANGE, 2", LOCKING FILL PORT	1
A	4300	FLANGE, 2", BASIN ALARM	1
	3502	FLANGE, 1/2", BASIN DRAIN	1
	SPECIAL	NO GPC STICKER ON TANK	1
	8420	ISOLATOR SUPPORT PLATE(BOTTOM)	4
	DW-101	SECONDARY CONTAINMENT	
BLACK		PAINT COLOR BLACK	









THIS AUTOCAD DRAWING IS THE PROPERTY OF GLOBAL POWER COMPONENTS AND MAY NOT BE USED IN ANY WAY DETRIMENTAL TO THE INTERESTS OF G.P.C. ANY MANUAL CHANGES WILL VOID THIS DRAWING. SPECIFICATIONS MAY CHANGE WITHOUT NOTICE. 1-1

REVISIONS				REVISIONS			
REV	DATE:	CHANGE MADE	BY	REV	DATE:	CHANGE MADE	BY
1	07/18	MOVED FITTINGS BASED ON FAX	KWS				

SUB BASE TANK W/ RUPTURE BASIN & STUB UP

CUSTOMER/ID: MQ POWER
JOB REF: X
DRAWING REF: X
DWG #: 15-10406
DATE: 07/15/04
DRAWN BY: KWS

Underwriters Laboratories, Inc. LISTED File No. MH18481

GLOBAL POWER COMPONENTS