






JOB #	TANK CAPACITY	GENSET MODEL	GENSET FOOTPRINT	TANK WEIGHT
10487	75 GAL	DCA45SSIU2	X	625 LBS

APPROVED BY: _____	DATE: _____
--------------------	-------------



LETTER/PART #	DESCRIPTION	QTY
S 3162	FLANGE, 2", EMERGENCY VENT	2
T 3650	FLANGE, 2", RETURN, W/ 1/2" DIPTUBE	1
U 3650	FLANGE, 2", SUPPLY, W/ 1/2" DIPTUBE	1
V 1000	FLANGE, 2", LOW LEVEL	1
X 1003	FLANGE, 2", FUEL LEVEL GAUGE	1
Y 3152	FLANGE, 2", STANDARD VENT	2
Z 3005	FLANGE, 2", LOCKING FILL PORT	1
A 4300	FLANGE, 2", BASIN ALARM	1
B 3195	FLANGE, 2", FITTING W/ PLUG	1
3502	FLANGE, 1/2", BASIN DRAIN	1
SPECIAL	NO GPC STICKER ON TANK	1
8420	ISOLATOR SUPPORT PLATE(BOTTOM)	4
DW-101	SECONDARY CONTAINMENT	
BLACK	PAINT COLOR BLACK	



WELD 1/4" SUPPORT
PLATES UNDER MOUNTING
HOLES SEE DETAIL
TYP(4X)

THIS AUTOCAD DRAWING IS THE PROPERTY OF GLOBAL POWER COMPONENTS AND MAY NOT BE USED IN ANY WAY DETRIMENTAL TO THE INTERESTS OF G.P.C. ANY MANUAL CHANGES WILL VOID THIS DRAWING. SPECIFICATIONS MAY CHANGE WITHOUT NOTICE.

REV	DATE	CHANGES	BY	REV	DATE	CHANGES	BY
1	08/16	MOVED MOUNTING HOLES & FITTINGS, SHORTENED TANK (75GAL) PER FAX	KWS				
2	08/16	HEIGHT TO 12" FOR 80 GALLONS	KWS				

SUB BASE TANK W/ RUPTURE BASIN & STUB UP

CUSTOMER/ID: MQ POWER

JOB REF: X

DRAWING REF: X

DWG #: 15-10487

DATE: 08/11/05

DRAWN BY: KWS

