


JOB #	TANK CAPACITY	GENSET MODEL	GENSET FOOTPRINT	TANK WEIGHT
10603	330 GAL	DCA220SSVU	51.18" x 143.7"	1600 LBS


APPROVED BY: _____ DATE: _____

BILL OF MATERIAL		
LETTER	PART #	DESCRIPTION
S	3162	FLANGE, 2", E-VENT
T	3650	FLANGE, 2", RETURN, W/ 1/2" DIPTUBE
U	3650	FLANGE, 2", SUPPLY, W/ 1/2" DIPTUBE
V	1000	FLANGE, 2", LOW LEVEL
X	1003	FLANGE, 2", FUEL LEVEL GAUGE
Y	3152	FLANGE, 2", STD VENT
Z	3005	FLANGE, 2", FILL PORT/LOCKING CAP
A	4300	BASIN ALARM, TOP MOUNT
	3502	FLANGE, 1/2", BASIN DRAIN
	8410	FLUSH MOUNT LIFTING PLATES
	8420	BOTTOM ISOPAD SUPPORT PLATE
	DW-101	SECONDARY CONTAINMENT
	BLACK	PAINT COLOR

**NO GPC STICKERS
ON TANK**



RADIATOR END



THIS AUTOCAD DRAWING IS THE PROPERTY OF GLOBAL POWER COMPONENTS AND MAY NOT BE USED IN ANY WAY DETRIMENTAL TO THE INTERESTS OF G.P.C. ANY MANUAL CHANGES WILL VOID THIS DRAWING. SPECIFICATIONS MAY CHANGE WITHOUT NOTICE. 1-1

REVISIONS			REVISIONS			SUB BASE TANK W/ RUPTURE BASIN & STUB UP	
REV	DATE:	CHANGE MADE	BY	REV	DATE:	CHANGE MADE	BY
						CUSTOMER/ID: MQ POWER	
						JOB REF: 24 HOUR TANK	
						QUOTE #: X	
						DWG #: 15-10603	
						DATE: 9/28/05	
						DRAWN BY: EHF	

