



- NOTES:
- 1- USE JUMPER WIRE PROVIDED FOR 50HZ OR 60HZ OPERATION
  - 2- FOR SE350, FUSE IS INTERNAL TO REGULATOR
  - 3- UNIT - PARALLEL SWITCH IS OPTIONAL AND NOT BY MEMC
  - 4- VAR (POTENTIOMETER) IS OPTIONAL

					✓ MAX. SURFACE ROUGHNESS UNLESS NOTED OTHERWISE	UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES TOL. ON XX± .02 XXX± .005 XXXX± .0005 ANGLES± 7'30"		
					MATL SPEC	DRAWN BY DRS 01-18-1999		
2	09-27-2000	ADDED IN-LINE FUSE AND REWORDED NOTE 4 CN 30046		TM	FINISH	CHKD BY TM 01-18-1999		
1	01-18-1999	NEW DRAWING GM-39614		DRS	APPD BY GK 01-18-1999			
REV	DATE	CHANGE	NAME	PART NAME CONNECTION DIAGRAM SE250/350/400 REG. & APM2000			DRWG NO B-525744-3044	
		SHOP BOOK	PURCHASED	DISTRIBUTION - WA - <del>X</del> - <del>X</del> - LM			CADD FILE NO. PM3044	

