



NOTES:

- 1- INSTALL 2000 OHM - 1/2 WATT POTENTIOMETER IN SERIES WITH VAR TERMINALS 6 AND 7 IF A REMOTE VOLTAGE CONTROL IS REQUIRED
- 2- USE JUMPER WIRE PROVIDED FOR 50Hz OR 60Hz OPERATION

				<input checked="" type="checkbox"/> MAX. SURFACE ROUGHNESS UNLESS NOTED OTHERWISE		UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES TOL. ON XX±    XXX±.005    XXXX±.0005    ANGLES±	
				MATL SPEC		DRAWN BY DRS 07-16-1998	
				FINISH		CHKO BY TM 07-16-1998 WAUSAU, WISCONSIN 54401 APPD BY LRM 07-16-1998	
1	07-16-1998	NEW DRAWING	GM-35919	DRS	PART NAME CONNECTION DIAGRAM		DRWG NO B-525744-3043
REV	DATE	CHANGE		NAME			
		SHOP BOOK	PURCHASED	DISTRIBUTION - WA - <del>X</del> - <del>X</del> - <del>X</del>		CADD FILE NO.	PM3043