
SERVICE BULLETIN

Original Issue Date: **2/97**
Model: **20-2000 kW**
Market: **Industrial**
Subject: **Safeguard Circuit Breaker Selection after Voltage Reconnection**

Some voltage reconnections require replacing the safeguard circuit breaker. Select the safeguard circuit breaker based on voltage and frequency. Failure to install the correct safeguard circuit breaker may cause inadequate generator set protection or nuisance circuit breaker tripping.

Use the Industrial Products Price List for the model and/or Price Bulletin 36 for selecting the safeguard circuit breaker based on the new voltage and frequency configuration.

Routing	Service Manager	Sales Manager	Parts Manager	Technician No. 1	Technician No. 2	Technician No. 3	Return This to
Initial Here							