



CUSTOMER APPROVAL SIGNATURE	APPROVAL DATE	COMMENTS
INCLUDED FEATURES		PART #
ENGINE: PERKINS 1106D-E66TAG2 (radiator through flywheel)		VAP J38420 1,563 Lbs.
ALTERNATOR: MARATHON		431CSL6202 1220 Lbs.
SUB-BASE: STRUCTURAL STEEL		V1087333 336 Lbs.
UL142 DOUBLE WALL BASKET/400 GALLONS		V12446132 1292 Lbs.
STANDARD ENCLOSURE		890 Lbs.
SIDE-IN TOP-OUT VERTICAL MOUNT SILENCER		62304 80 Lbs.
ISOLATORS: (4) ERCD 4960060		V14960060 12 Lbs.
FUEL SYSTEM		V1TRU03110 MISC.
OIL DRAIN EXTENSION: WITH VALVE ROUTED TO SKID		V1T204N MISC.
CABLE AND WIRING		N/A MISC.
HARDWARE (BOLTS, WASHERS, HINGES, & LATCHES)		N/A MISC.
(1) BATTERIES: GROUP 31 STYLE 12V BATTERY RACK AND CABLES FOR BATTERY		VT31P6 41 Lbs.
Note: Rack is integral to the skid		
CONTROL PANEL		MISC.
CIRCUIT BREAKER: ABB		xxxx MISC.
ABB ENCLOSURE		xxxx MISC.
WEIGHT SUBTOTAL		5,434 Lbs.
MISC. WEIGHT: 5% of subtotal		272 Lbs.
TOTAL WEIGHT OPEN UNIT:		5,706 Lbs.

ENCLOSURE MATERIAL: 14 ga. Galvaneal
 COLOR: AkzoNobel Clay #20-8247HY POWDER COAT

DRAWN	6/13/2011	TITLE	
JOHN		TAYLOR POWER SYSTEMS	
CHECKED		Standard Enclosure	
QA		Model TD140 (400 GAL)	
MFG		SIZE	DWG NO
APPROVED		C	TD125 to TD175 New Enc
		SCALE	REV
			SHEET 1 OF 1