



CUSTOMER APPROVAL SIGNATURE	APPROVAL DATE	COMMENTS	
INCLUDED FEATURES		PART #	WEIGHT
ENGINE: PERKINS 1104D-E44TAGI (radiator through flywheel)		VANJ38673	1,042 Lbs.
ALTERNATOR: MARATHON		43ICSL6204	1310 Lbs.
SUB-BASE: STRUCTURAL STEEL		VT087333	336 Lbs.
UL142 DOUBLE WALL BASETANK 600 gallons		VT3646132	1675 Lbs.
SOUND ATTEN. ENCLASURE			890 Lbs.
ISOLATORS: (4) EBCI 4960060		VT4960060	12 Lbs.
BLOCK HEATER: 1000 WATT / 120 VOLT / 8.3 AMPS		VT3305044	MISC.
FUEL SYSTEM:		VTGRU03110	MISC.
OIL DRAIN EXTENSION WITH VALVE ROUTED TO SKID		VTT204N	MISC.
CABLE AND WIRING		N/A	MISC.
HARDWARE (BOLTS, WASHERS, HINGES, & LATCHES)		N/A	MISC.
(4) BATTERIES: GROUP 31 STYLE 12V BATTERY RACK AND CABLES FOR BATTERY Note: Rack is integral to the skid		VT31P6	41 Lbs.
CONTROL PANEL: Digital Auto Start			MISC.
CIRCUIT BREAKER: ABB ABB ENCLASURE		xxxx xxxx	MISC.
WEIGHT SUBTOTAL			5,306 Lbs.
MISC. WEIGHT 5% of subtotal			265 Lbs.
TOTAL WEIGHT OPEN UNIT:			5,571 Lbs.

DRAWN John	6/13/2011	TAYLOR POWER SYSTEMS	
CHECKED		TITLE	
QA		TD175 With 600 Gal. Basetank	
MFG			
APPROVED			
		SIZE C	DWG NO TD125 to TD175 New Enc
		SCALE	REV
		SHEET 1 OF 1	