



CUSTOMER APPROVAL SIGNATURE	APPROVAL DATE	COMMENTS
INCLUDED FEATURES		
ENGINE: PERKINS 1106D-E661AG4 (radiator through flywheel)	PJ38421	1,574 Lbs.
ALTERNATOR: MARATHON	43ICSL6204	1310 Lbs.
SUB-BASE: STRUCTURAL STEEL	VT087333	336 Lbs.
STANDARD ENCLOSURE		890 Lbs.
SIDE IN TOP OUT VERTICAL MOUNT SILENCER	VT62304	80 Lbs.
ISOLATORS: (4) EBCD 4960060	VT4960060	12 Lbs.
FUEL SYSTEM	VTGRU03110	MISC.
OIL DRAIN EXTENSION: WITH VALVE ROUTED TO SKID	VT1204N	MISC.
CABLE AND WIRING	N/A	MISC.
HARDWARE (BOLTS, WASHERS, HINGES, & LATCHES)	N/A	MISC.
CONTROL PANEL		MISC.
CIRCUIT BREAKER: ABB	xxxxx	MISC.
ABB ENCLOSURE	xxxxx	MISC.
WEIGHT SUBTOTAL		4,202 Lbs.
MISC. WEIGHT: 5% of subtotal		210 Lbs.
TOTAL WEIGHT OPEN UNIT:		4,412 Lbs.

DESIGN	6/13/2011	TAYLOR POWER SYSTEMS	
DATE		TITLE	
CHECKED		TD175 Standard Enclosure	
QA		SIZE	DWG NO
APP'G		C	TD125 to TD175 New Enc
APPROVED		SCALE	REV
			SHEET 1 OF 1