



CUSTOMER APPROVAL SIGNATURE	APPROVAL DATE	COMMENTS
INCLUDED FEATURES		
ENGINE: MTU	6R1600/70S	3,100 Lbs.
Generator through flywheel)		
ALTERNATOR MARCHION 433 FRAME	433CSL6216	2,235 Lbs.
SUB-BASE: STRUCTURAL STEEL	V1087316	811 Lbs.
SKID EXTENSION: STRUCTURAL STEEL		288 Lbs.
STANDARD ENCLOSURE		167 Lbs.
SIDE-IN TOP-OUT VERTICAL MOUNT SILENCER	V162305	118 Lbs.
315 GALLON BASETANK	V11266162	1792 Lbs.
ISOLATORS: (4) LF3700	V1LF3700	12 Lbs.
(2) LF42100	V1LF42100	15 Lbs.
FLEX FUEL LINES		MISC.
WIRE AND CABLE		MISC.
FLUIDS		MISC.
STAINLESS HARDWARE (BOLTS, HINGES, ETC.)		MISC.
CONTROL PANEL		MISC.
CIRCUIT BREAKER: ABB		MISC.
WEIGHT SUBTOTAL		9988 Lbs.
MISC. WEIGHT: 5% of subtotal		499 Lbs.
TOTAL WEIGHT:		10,487 Lbs.

DRAWN	JWM	4/21/11	TITLE	TAYLOR POWER SYSTEMS
CHECKED				
QA				
MFG				
APPROVED				
SIZE				
SCALE				

TD275
STANDARD ENCLOSURE
315 GALLON BASETANK