



CUSTOMER APPROVAL SIGNATURE	APPROVAL DATE	COMMENTS
		INCLUDED FEATURES:
		ENGINE BEARING 2880C-518143 Electric (generator through flywheel)
		VAE181A43 4,520 Lbs.
		ALTERNATOR MOUNTATION 51785A,4333 3,400 Lbs.
		SUB-BASE STRUCTURAL STEEL V17087704 909 Lbs.
		ENCLOSURE CLAY POWDER COAT, 14 GA. STEEL V1708008 1850 Lbs.
		STAND ATTENMANTED
		SLENDER SIDE-IN TOP-DOT VERTICAL MOUNT V162388 305 Lbs.
		475 GALLON ULHZ DOUBLE WALL SUB BASTANK V1727228 2738 Lbs.
		7 GALLON SPILL BOX AND 1/2" ABOVE GRADE VENT AND CHANNELS OVER FANK V17173200 12 Lbs.
		INSULATORS (4) U174200 V174200 30 Lbs.
		FLEX FUEL LINES V17600125 MISC.
		OIL BRAIN EXTENSION 1" VALVE IN SPD V1712000 MISC.
		OIL BRAIN EXTENSION V1780 MISC.
		(2) BATTERIES 80 STILE RACK AND CABLES FOR (2) BATTERIES (note rack is integral to the sub) MISC. 150 Lbs.
		CONTROL PANEL MISC. XXXX
		CIRCUIT BREAKER ABB BREAKER ENCLOSURE MISC. XXXX
		WEIGHT SUBTOTAL 13914 Lbs.
		MISC. WEIGHT 5% of subtotal 696 Lbs.
		TOTAL WEIGHT: 14610 Lbs.

ENCLOSURE MATERIAL: 12 & 14 ga. Galvaneal
 COLOR: Akzonobel Clay #20-8247HY POWDER COAT

DESIGN	DATE	TITLE	SCALE
01/19/2012		TAYLOR POWER SYSTEMS	
DESIGNED		TD600 SA ENCLOSURE	
BY		475 GALLON BASTANK	
APPROVED			