



CUSTOMER APPROVAL SIGNATURE	APPROVAL DATE	COMMENTS
INCLUDED FEATURES		
ENGINE: PERKINS 1104D-E44TGI (radiator through flywheel)	VANH75030	1,062 Lbs.
ALTERNATOR: MARATHON	361CSL1602	620 Lbs.
SUB-BASE: STRUCTURAL STEEL	VT1087372	288 Lbs.
UL142 DOUBLE WALL BASETANK 295 gallons	VT2446102	1066 Lbs.
STANDARD ENCLOSURE	VT62303	713 Lbs.
SIDE-IN TOP-OUT VERTICAL MOUNT SILENCER	VT62303	45 Lbs.
ISOLATORS: (4) LF2650	VTLE2650	12 Lbs.
FUEL SYSTEM:	VTGRU03110	MISC.
OIL DRAIN EXTENSION: WITH VALVE ROUTED TO SKID	VTT204N	MISC.
CABLE AND WIRING	N/A	MISC.
HARDWARE (BOLTS, WASHERS, HINGES, & LATCHES)	N/A	MISC.
(1) BATTERIES: GROUP 31 STYLE 12V BATTERY RACK AND CABLES FOR BATTERY Note: Rack is integral to the skid	VT31P6	41 Lbs.
CONTROL PANEL		MISC.
CIRCUIT BREAKER: ABB	xxxx	3 Lbs.
ABB ENCLOSURE	xxxx	7 Lbs.
WEIGHT SUBTOTAL		3857 Lbs.
MISC. WEIGHT: 5% of subtotal		193 Lbs.
TOTAL WEIGHT OPEN UNIT:		4,050 Lbs.

ENCLOSURE MATERIAL: 12 & 14 ga. Galvaneal
 COLOR: AkzoNobel Clay #20-8247HY POWDER COAT

DRAWN	6/13/2011	TITLE	TAYLOR POWER SYSTEMS
CHECKED	JOHN	MODEL	Standard Enclosure
QA		DESCRIPTION	Model TD60 with 295 gallon basetank
MFG		SIZE	C
APPROVED		DWG NO	TD55 to TD100 enc
		SCALE	
		REV	