



CUSTOMER APPROVAL SIGNATURE	APPROVAL DATE	COMMENTS
INCLUDED FEATURES	PART #	WEIGHT
ENGINE: PERKINS 1104D-E44TAG1 (radiator through flywheel)	VANJ38672	1,025 Lbs.
ALTERNATOR: MARATHON	362CSL1604	706 Lbs.
SUB-BASE: STRUCTURAL STEEL	V7087372	288 Lbs.
UL142 DOUBLE WALL BASETANK 295 gallons	V72446102	1066 Lbs.
STANDARD ENCL.SUORE		713 Lbs.
SIDE IN TOP OUT VERTICAL MOUNT SILENCER	V762303	45 Lbs.
ISOLATORS: (4) LF2650	V7LF2650	12 Lbs.
FUEL SYSTEM:	V7GRU03110	MISC.
DIL DRAIN EXTENSION: WITH VALVE ROUTED TO SKID	V7T204N	MISC.
CABLE AND WIRING	N/A	MISC.
HARDWARE (BOLTS, WASHERS, HINGES, & LATCHES)	N/A	MISC.
(1) BATTERIES: GROUP 31 STYLE 12V BATTERY RACK AND CABLES FOR BATTERY Note: Rack is integral to the skid	V731P6	41 Lbs.
CONTROL PANEL		MISC.
CIRCUIT BREAKER: ABB	xxxx	3 Lbs.
ABB ENCLDSURE	xxxx	7 Lbs.
WEIGHT SUBTOTAL		3,906 Lbs.
MISC. WEIGHT: 5% of subtotal		195 Lbs.
TOTAL WEIGHT OPEN UNIT:		4,101 Lbs.

ENCLOSURE MATERIAL: 12 & 14 ga. Galvaneal
 COLOR: AkzoNobel Clay #20-8247HY POWDER COAT

DRAWN	6/13/2011	TAYLOR POWER SYSTEMS	
CHECKED	John	Standard Enclosure	
QA		Model TD80 with 295 gallon	
MFG		basetank	
APPROVED		SIZE	DWG NO
		C	TD55 to TD100 enc
		SCALE	REV
			SHEET 1 OF 1