
0626-2252	D	Pro/ENGINEER	2D ONLY DWG

REL NO	LTR	NO	REVISION	ZONE	DR	CHKR	APPROVED	DATE
FRD21067	F	1	REDRAWN ON PROE	-	SDM	IAM	MILLER	08-01-04


OPTION WIRING

REAR VIEW OF DOOR



LEFT SIDEWALL

REAR WALL OF CABINET



NOTES:

6. A JUMPER IS CONNECTED BETWEEN TB2-2 AND TB2-3 WHEN USED WITH A GENSET WITH A POSITIVE START SIGNAL. A JUMPER IS CONNECTED BETWEEN TB2-2 AND TB2-1 WHEN USED WITH A GENSET WITH A NEGATIVE START SIGNAL.

QTY -01	ITEM	PART NO	DWG SIZE	DESCRIPTION OR MATERIAL	REF DES

DO NOT SCALE PRINT

TOLERANCE UNLESS OTHERWISE SPECIFIED

DIM	mm	inch
	X ±	X ±
	.X ±	.XX ±
	.XX ±	.XXX ±
NOTE	0.00-4.99 ±0.15/-0.08 5.00-9.99 ±0.20/-0.10 10.00-17.49 ±0.25/-0.13 17.50-24.99 ±0.30/-0.13	.000-.200 ±.006/-.003 .201-.421 ±.008/-.004 .422-.703 ±.010/-.005 .704-.999 ±.012/-.005

ANG TOL± 1°

DRAWN TO SCALE OF 1/1

SIZE FO

COPIED FROM

THIRD ANGLE PROJECTION

THIS DOCUMENT IS THE PROPERTY OF CUMMINS POWER GENERATION. IT CONTAINS PROPRIETARY AND CONFIDENTIAL INFORMATION WHICH MUST NOT BE DUPLICATED, USED OR DISCLOSED OTHER THAN EXPRESSLY AUTHORIZED BY CUMMINS POWER GENERATION OR ITS REPRESENTATIVE

	NAME	DATE
DR	S D MORE	08/01/04
CHKR ☒ MFG ☐	I A MAHADESHWAR	08/01/04
APPROVED	MILLER	08/01/04

FOR INTERPRETATION OF DIMENSIONING AND TOLERANCING, SEE ANSI Y14.5M-1982

MODEL FIRST USED ON: LT 30-60 AMP,SPEC J

SITE CODE: PGA

CUMMINS POWER GENERATION
4400 73RD AVE NE
MINNEAPOLIS, MINNESOTA 55432

TITLE: WD-TRANSFER SWITCH

DWG NO: 0626-2252

SHEET: 5 of 5

DWG SIZE: D